

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 1060-0049:006 Page 1 of 1

CATEGORY: Structural Members

LISTEE: Chicago Metallic, 4849 S. Austin Ave., Chicago IL 60638
Contact: Tony Ingratta (708) 563-4600

DESIGN: Normal weight concrete over 3/8" rib lath supported on steel bar joists which are supported by 10x21 steel beam. Protected light and duct openings in a gypsum board ceiling supported by furring tee bars and furring wall tracks. Refer to listee's data sheet for detailed product description, assembly components and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Furring members bear UL label.

APPROVAL: Listed as a 2-hour fire-rated ceiling/floor or ceiling/roof assembly; 3-hour fire-rated beam.

NOTE: Beam shall be independently protected when it supports more than one floor or one floor and the roof.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 29, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager